



# New Jersey Burglar & Fire Alarm Association

202 West State Street • Trenton, NJ 08608  
 1.800.577.3323 • 609.695.4444 • (fax) 609.695.3333  
 (website) njbfaa.org • (e-mail) membership@njbfaa.org

## **2012 AWARD NOMINATION FORM**

Nominee Name:	Joe Technician		
Company:	NJBFAA Alarm Company		
Address:	202 West State Street Trenton, NJ		
Phone:	609-695-4444	Email:	membership@njbfaa.org
Award Category:	<input type="checkbox"/> The Paul Baran <u>Residential Installation</u> of the Year Award <input type="checkbox"/> The Paul Baran <u>Commercial Installation</u> of the Year Award <input checked="" type="checkbox"/> The Gary Licknack <b>Life Safety Installation</b> of the Year Award		
Your Name:	A.J. Owner		
Your Company:	NJBFAA Alarm Company		
Your Phone:	609-695-4444	Email:	Membership@NJBFAA.ORG

**SAMPLE**

### **NOMINATION INSTRUCTIONS**

- Complete this entry form for each award category (copies are accepted).
- On a **separate sheet of paper**, please state why your entry meets or exceeds the judging criteria as outlined and should be considered as a finalist and/or winner.
- **For the installation awards, a minimum of 3 and a maximum of 10 - 8' X 10' photos must be attached (1 – panel or head end, 2 – installed cabling, 3 - device)**
- All entries must be submitted by mail to:  
  
**NJBFAA – AWARD NOMINATIONS DEPARTMENT**  
**202 West State Street**  
**Trenton, NJ 08608**
- Entries must be received by **January 27, 2012**. All entries become the property of NJBFAA and cannot be returned.

### **System Components**

- 1      Addressable Fire Alarm Control With A Built In DACT
- 2      Remote Annunciators
- 87     Addressable Smoke Detectors
- 40     Heat Detectors
- 20     Manual Pull Stations
- 4      Duct Smoke Detectors
- 32     Combination Horn/Strobes
- 2      Stand Alone Strobes
- 1      4 Loop NAC Expander/Booster
- 5      Addressable Relay Modules

### **Type of Building: 4 Story R-2 Apartment Building**

The system is installed in the common areas of the building. A fire broke out in the elevator shaft and activated multiple smoke detectors in the 1<sup>st</sup> floor lobby and hallway. The elevator was occupied during the alarm by 3 adults and 2 children. Upon activation of the detectors the elevator recalled to the alternate floor and activated the buildings audio and visual devices. The Central Station dispatched the fire department in 10 seconds upon receipt of the fire alarm signal. The fire was under control within 15 minutes and potentially saved the lives of the 5 individuals in the elevator and over 100 tenants due to the on site audio/visual notification of the horn/strobes and the quick response of the fire department.

**Attached would be 3 – 8x10 photos: (1 – panel or head end, 2 – installed cabling, 3 - device)**